

# INDEX

---

- Accepted installation, 9
- Accepted product, 9
- Aerosol Products*, NFPA 30B, 2
- Air Conditioning and Ventilating Systems*, NFPA 90A, 5
- Air, environmental, 5
- Alarm valve, 22
- Allowance, stream, 46
- Allowed pipe, 21
- Alloy, fusible, 10
- American National Standards Institute (ANSI) *Elevator Code*, 5
- Annunciator, remote, 12
- ANSI, 5
- Antifreeze, 18
- Appliance, 46
- Approval of equipment, 9
- Approved for location, 51
- Area
  - covered by sprinkler, 35
  - design, 31
  - hydraulically most-demanding, 31
  - sprinkler protection, 31
- Area/density method, 31
- Assembly, 46
- Autogeneous ignition temperature, 49
- Autoignition temperature, 49
- Automatic Fire Detectors*, NFPA 72E, 11
- Automatic sprinkler systems with nonfire protection connections, 20
  
- Backflash interrupter, 53
- Backup power, 12
- Baffle, 34
- Barrel, wet, 26
- Base of riser, 45
- Basic Building Code*, 1
- Battery power supply, 12
- Bell, 11
- Belt, conveyor, 7
- Bimetallic detector, 10
- Bladder, 25
- BOCA, 1
- Booster pump, 26
- Bracing, 22
- Branch line, 21
- Branch, pressure along, 39
  
- Building Officials and Code Administrators (BOCA), 1
- Building classification, 3
- Building fuel loading, 3
- Bureau of Mines, 9
- Bursting-panel relief vent, 53
- Buzzer, 12
- Bypass meter, valve, 25
  
- Cable, teflon-coated, 5
- Calculation, hydraulic, 38
- Can, safety, 6
- Capacity, overload, 27
- Capacity, rated (100%), 27
- Capture, elevator, 5
- Carbon dioxide system, 8, 17
- Cast iron, 21
- Ceiling, drop, 5
- Ceiling height, 34
- Certified product, 9
- Check valve, 22
- Chemical extinguishment, 14
- Chemical-responsive system, 53
- Chemical system, dry, 15
- Chime, 11
- Chlorinated polyvinyl chloride (CPVC), 21
- Churn, 27
- Circulating closed-loop system, 20
- Classes of extinguishers, 14, 49
- Classification, building, 3
- Classification, hazard, 1
- Closed-loop system, circulating, 20
- Coal, 6
- Coefficient, C, 36
- Coefficient, Hazen-Williams, 36
- Coefficient of discharge, nozzle, 46
- Combustible liquid, 49
- Combustible structures, 2
- Combustion, engine, 8
- Combustion, fluidized bed (FBC), 8
- Compartment, enclosed, 8
- Composite structural member, 4
- Condition, explosive, 48
  
- Connection
  - cross-main, 42
  - pumper, 26
  - steamer, 26
- Constant
  - nozzle, 30
  - orifice, 30
- Construction, types of, 2, 3, 4
- Containers, limits on, 5
- Containment, explosion, 53
- Content, fuel, 3
- Control panel, 12
- Control, smoke, 4
- Control valves, types of, 22
- Conventional sprinkler system, 19
- Conveyor belt, 7
- Copper tube, 21
- Corridor, 35
- Coverage per sprinkler, 30
- CPVC pipe, 18, 21, 22
- Cross-main, 21
  - pressure at, 42
- Cross-main connection, 42
- Curve
  - supply, 23
  - system loss, 23
- C-value, 36
- Cycle system, 24
  
- Dampers, types of, 4
- Deflagration, 48
- Deluge water sprinkler system, 18
- Density
  - discharge, 32
  - vapor, 49
- Design area, 31
- Design concept, hydraulic, 38
- Design, schedule, 35
- Destratification fan, 11
- Detectors, types of, 10, 11
- Detonation, 48
- Device, 46
  - isolation, 50
  - pressure-reducing, 23
- Diesel engine, 27
- Dilution ventilation, 54

- Discharge
  - propagating brush, 52
  - static, 51
- Discharge characteristics, sprinkler, 29
- Discharge coefficient, nozzle, 46
- Discharge coefficient, orifice, 30
- Discharge density, 32
- Discharge from sprinkler, 29
- Distance between sprinklers, 33
- Diverter, flame-front, 53
- Division 1 environment, 51
- Division 1 motor, 50
- Division 1 occupancy, 50
- Division 2 environment, 51
- Doors
  - explosion-relief, 53
  - types of, 4
- Drainage, 8
- Drawdown, 24
- Drive, electric, 27
- Drop ceiling, 5
- Dry chemical system, 15
- Dry pipe sprinkler system, 17
- Dry pipe system, preaction, 18
- Dry standpipe, 15
- Duct, 5
- Ducts and plenums, smoke detectors
  - used in, 5
- Dust collection system, 7
- Dust explosion, 48
- Dust, metal, 52
- Dust suppression system, 7
  
- Efficiency factor, mixing, 54
- Elbow, reducing, 37
- Electrical metallic tubing (EMT), 5
- Electric drive, 27
- Electricity, static, 51
- Electrostatic precipitators (ESP), 8
- Elevator capture, 5
- Elevator Code*, American National Standards Institute (ANSI), 5
- Emergency and Standby Power Systems*, NFPA 110, 12
- EMT, 5
- Encasement, 4
- Enclosed compartment, 8
- Engine
  - combustion, 8
  - diesel, 27
- Environment
  - Division 1, 51
  - Division 2, 51
- Environmental air, 5
- Epitropic filter fabric, 52
- Equation, Hazen-Williams, 36
- Equipment
  - approval of, 9
  - explosion-proof, 51
  - pulverizing, 7
  - purged and pressurized, 51
- ESP, 8
- Explosion, 48
  - dust, 48
  - secondary, 48
- Explosion containment, 53
- Explosion hazard classification, 50
- Explosion pressure, maximum, 49
- Explosion prevention system, 50
- Explosion-proof equipment, 51
- Explosion propagation, 53
- Explosion relief, 53
- Explosion suppression, 52
- Explosion vent, 50
- Explosion venting, 53
- Explosive condition, 48
- Explosive limit, 49
- Explosive limit, lower, (LEL), 49
- Explosive limit, upper, (UEL), 49
- Extinguisher, portable, 14
- Extinguishers, classes of, 14
- Extinguishment, chemical, 14
- Extra hazard groups, 2
- Extra hazard occupancy, 2
  
- Fabric
  - epitropic filter, 52
  - filter, 7
- Factory Mutual Research Corporation (FM), 9
- Fan, destratification, 11
- Fast-acting gate valve, 53
- Fault tolerance, 51
- FBC, 8
- Feed main, 21
- Ferrous pipe, 21
- FGD, 7
- Filter fabric, 7
- Fire damper, 4
- Fire door, 4
- Fire hazard, 1
- Fire hydrant, 26
- Fire loading, 3
- Fire point, 49
- Fireproof, 2
- Fireproofing, sprayed-on, 4
- Fire pump, 26
- Fire-resistive construction, 3
- Fitting, 36
- Fixed water sprinkler system, 17
- Fixed-temperature heat detector, 10
- Flame detectors, types of, 11
- Flame-front diverter, 53
- Flammable liquid, 49
- Flammable Liquids Code*, NFPA 30, 2, 5
- Flash point, 48
- Flexibility, 22
- Flexible hose, 6
- Flow measurement, 25
- Flow rate, minimum, 24
- Flue gas desulfurization (FGD) system, 7
- Fluidized bed combustion (FBC), 8
- FM, 9
- Foam, 16
- Fraction of air in tank, 25
- Friction loss in hose, 46
- Friction loss in pipe, 36
- Fuel content, 3
- Fuel loading, building, 3
- Fusible alloy, 10
- Fusible link sprinkler, 28
  
- Gas detector, 11
- Gas turbine, 8
- Gate valve, fast-acting, 53
- General Storage*, NFPA 231, 2, 29
- Glass bulb sprinkler, 28
- Glycerine, 18
- Graphical solution, 36
- Gravity tank, 25
- Gridded system, 20
- Ground tank, 25
- Grounding, 52
- Groups, hazard, 2
- Gypsum wallboard, 4
  
- Halon 1211, 16
- Halon 1301, 8, 16
- Halon system, 16
- Hammer, water, 22
- Hanger, 21
- Hazard classification, 1
- Hazard classification, explosion, 50
- Hazard, fire, 1
- Hazard type, occupancy, 1
- Hazen-Williams C-value, 36
- Hazen-Williams equation, 36
- Head
  - rated (100%), 27
  - sprinkler, 28
- Heat detectors, 10
- Heating value, 3
- Heavy timber construction, 2
- Height, ceiling, 34
- High temperature-rated sprinkler, 29
- High-piled storage system, 2
- Horizontal pump, 26
- Hose
  - flexible, 6
  - friction loss in, 46
- Hose Connection Threads*, NFPA 1963, 26
- Hose lengths, 26
- Hose nozzle, straight-stream, 16
- Hose stream, 46
- Hose system, 15
- Hydrant, fire, 26
- Hydraulically most-demanding area, 31
- Hydraulically most-remote nozzle, 38
- Hydraulic calculation, 38
- Hydraulic design concept, 38
- Hydraulic junction point, pressure at, 43
- Hydraulic system, 6
- Hydropneumatic steel water tank, 25
  
- ICBO, 1
- Ignition energy (MIE), minimum, 49
- Ignition, source of, 51
- Ignition temperature, 49
- Impairment, 47
- Impeller location, 26, 27
- Inerting, 52
- Infrared flame detector, 11
- Inspection, 47
- Installation, accepted, 9
- Interference, solar, 11
- Intermediate temperature-rated sprinkler, 29

- International Congress of Building Officials (ICBO), 1
- Interrupter, backflash, 53
- Intrinsically safe, 50, 51
- Intumescent, 4
- Ionization detector, 10
- Ionizer, 52
- Iron, cast, 21
- Isolation, 50
- Isolation device, 50
- Isolation system, passive-mechanical, 53
  
- Jockey pump, 27
  
- K-factor, 30
  
- Labeled product, 9
- LEL, 49
- Life Safety Code*, NFPA 101, 1
- Light hazard occupancy, 2
- Light, strobe, 12
- Limit explosive, 49
- Limits on containers, 5
- Limits, volumetric, 5
- Line
  - branch, 21
  - phone, 13
- Linear-beam smoke detector, 10
- Link-and-lever sprinkler, 28
- Liquid
  - combustible, 49
  - flammable, 49
- Liquids, classes of, 49
- Listed product, 9
- Loading
  - fire, 3
  - fuel, 3
- Location, approved for, 51
- Loop system, 20
- Loss
  - friction, 36
  - minor, 36
- Lower explosive limit (LEL), 49
  
- Magnesium oxychloride, 4
- Main, feed, 21
- Maintenance, 47
- Makeup pump, 27
- Manual station, 10
- Material, pyphoric, 51
- Maximum explosion pressure, 49
- Maximum rate of pressure rise, 49
- Measurement, flow, 25
- Mechanical-responsive system, 53
- Membrane protection, 4
- Metal dust, 52
- Method, area/density, 31
- MIE, 49
- Mine Safety and Health Administration (MSHA), 9
- Minimum flow rate, 24
- Minimum ignition energy (MIE), 49
- Minimum working pressure, 21
- Minor loss, 36
- Mixing efficiency factor, 54
- Monoammonium phosphate, 15
  
- Motor, Division 1, 50
- MSHA, 9
  
- National Fire Protection Association (NFPA), 1
- Nationally recognized testing laboratory (NRTL), 9
- NEAT, 5
- NFPA, 1
- NFPA 1, *NFPA Fire Prevention Code*, 1
- NFPA 10, *Portable Fire Extinguishers*, 15
- NFPA 101, *Life Safety Code*, 1
- NFPA 110, *Emergency and Standby Power Systems*, 12
- NFPA 110A, *Stored Emergency Systems*, 12
- NFPA 13A, *Sprinkler Maintenance*, 8
- NFPA 14, *Standpipe and Hose Systems*, 15
- NFPA 15, *Water Spray Fixed Systems*, 4, 19
- NFPA 1963, *Hose Connection Threads*, 26
- NFPA 204M, *Smoke and Heat Venting Guide*, 5
- NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 25
- NFPA 231, *General Storage*, 2, 29
- NFPA 231C, *Rack Storage of Materials*, 4, 29
- NFPA 231D, *Storage of Rubber Tires*, 2
- NFPA 24, *Private Fire Service Mains*, 23, 26
- NFPA 30, *Flammable Liquids Code*, 2, 5
- NFPA 30B, *Aerosol Products*, 2
- NFPA 72E, *Automatic Fire Detectors*, 11
- NFPA 90A, *Air Conditioning and Ventilating Systems*, 5
- Noncombustible construction, 3
- Nonfire protection connections, automatic sprinkler systems with, 20
- Nonmetallic environmental airspace tubing (NEAT), 5
- Nonmetallic pipe, 21
- Normal pressure, 38
- Nozzle, 46
  - hose, straight-stream, 16
  - hydraulically most-remote, 38
  - solid-stream, 46
  - spray, 46
- Nozzle constant, 30
- Nozzle discharge coefficient, 46
- NRTL, 9
- Number of sprinklers, 31
  
- Occupancy
  - Division 1, 50
  - extra hazard, 2
  - light hazard, 2
  - ordinary hazard, 2
- Occupancy hazard type, 1
- Occupational Safety and Health Administration, OSHA, 1
- Oil-insulated transformer, 8
- Ordinary construction, 3
  
- Ordinary hazard group 1, 2
- Ordinary hazard group 2, 2
- Ordinary hazard occupancy, 2
- Ordinary temperature-rated sprinkler, 28
- Orifice constant, 30
- Orifice discharge coefficient, 30
- OSHA, 1, 9
- Outside-stem-and-yoke (OS&Y) control valve, 22
- Overload (65%), capacity, 27
  
- Panel, control, 12
- Particle size, 10
- Passive-mechanical isolation system, 53
- Pendant sprinkler, 28
- Period of service, 29
- Phone line, 13
- Photoelectric detector, 10
- Photoelectric flame detector, 11
- PI, 22
- Pipe, types of, 18, 19, 20, 21, 22
- Piping, 21
- PKP, 15
- Plant, power, 6
- Playpipe, 46
- Plenum, 5
- Point
  - fire, 49
  - flash, 48
- Polybutylene pipe, 21, 22
- Polypropylene, 7
- Polyvinyl chloride (PVC), 7
- Portable extinguisher, 14
- Portable Fire Extinguisher*, NFPA 10, 15
- Portable tank, 5
- Post-indicating (PI) control valve, 22
- Potassium bicarbonate, 15
- Potassium chloride, 15
- Power
  - backup, 12
  - battery, 12
  - standby panel, 12
- Power plant, 6
- Preaction dry pipe system, 18
- Precipitators, electrostatic (ESP), 8
- Pressure
  - explosion, maximum, 49
  - minimum working, 21
  - normal, 38
  - rise, maximum rate of, 49
  - static, 24, 38
  - velocity, 37
- Pressure along branch, 38
- Pressure at cross-main, 42
- Pressure at hydraulic junction point, 43
- Pressure at the roof, 24
- Pressure in riser, 45
- Pressure-maintenance pump, 27
- Pressure rating, 21
- Pressure-reducing device, 23
- Pressure-regulating (PRV) valve, 23
- Pressure steel water tank, 25
- Pressure supply, 24
- Pressure switch, 11
- Pressurization, 5
- Prevention system, explosion, 50

- Primary detector, 10
- Private Fire Service Mains*, NFPA 24, 23, 26
- Process tank, 34
- Products, types of, 9
- Propagating brush discharge, 52
- Propagation, explosion, 53
- Properties, thermal, 3
- Propylene glycol, 18
- Protection area, 31
- Protection membrane, 4
- PRV, 23
- Pull station, 10
- Pulverizing equipment, 7
- Pump, jockey, 27
- Pump, makeup, 27
- Pump, pressure-maintenance, 27
- Pump, submersible turbine, 26
- Pump, sump, 26
- Pumper connection, 26
- Pumps, types of, 26
- Purged and pressurized equipment, 51
- Purging, 51, 52
- Purple K, 15
- PVC, 7
- Pyphoric material, 51
  
- Quick-burning construction, 3
  
- Rack Storage of Materials*, NFPA 231C, 4, 29
- Rate-compensated heat detector, 10
- Rated (100%) capacity, 27
- Rated (100%) head, 27
- Rate of rise detector, 10
- Rating
  - pressure, 21
  - temperature, 29
- Record keeping, 8
- Reducer, 36
- Reducing elbow, 36
- Relief, explosion, 53
- Relief vent, 53
- Remote annunciator, 12
- Residential sprinkler system, 19
- Riser, 21
  - base of, 45
  - pressure in, 45
- Roof
  - vent, 5
  - pressure at, 24
  
- Safety can, 5
- SBCCI, 1
- Schedule design, 35
- Schedule pipe, 19
- Scrubber, wet, 7
- Secondary detector, 11
- Secondary explosion, 48
- Self-ignition temperature, 49
- Service, period of, 29
- Shutoff, 27
- Sidewall sprinkler, 28
- Signaling, 12
- Single-fault tolerant, 51
- Siren, 12
  
- Size, particle, 10
- Smoke and Heat Venting Guide*, NFPA 204M, 5
- Smoke control, 4
- Smoke damper, 4
- Smoke detector, 10
- Smoke detectors used in ducts and plenums, 5
- Smoke door, 4
- Sodium bicarbonate, 15
- Solar, interference, 11
- Solder puck sprinkler, 28
- Solid state detector, 10
- Solid-stream nozzle, 46
- Solution, graphical, 36
- Source of ignition, 51
- Sources of water, 24
- Southern Building Code Congress International (SBCCI), 1
- Speaker, 12
- Spray, 16
- Sprayed-on fireproofing, 4
- Spray nozzle, 46
- Sprinkler life, 29
- Sprinkler Maintenance*, NFPA 13A, 8
- Sprinklers
  - area covered by, 35
  - coverage per, 30
  - discharge characteristics, 29
  - temperature ranges, 29
  - temperature-rated, high, 29
  - temperature-rated, intermediate, 29
  - types of, 28
- Sprinkler systems, types of, 17, 18, 19
- Sprinkler systems with nonfire protection connections, automatic, 20
- Squib, 53
- Standard Building Code*, 1
- Standard for Water Tanks for Private Fire Protection*, NFPA 22, 25
- Standby panel power, 12
- Standpipe, 15
- Standpipe and Hose Systems*, NFPA 14, 15
- Standpipe system, 15
- Static discharge, 51
- Static electricity, 51
- Static pressure, 24, 38
- Station
  - manual, 10
  - pull, 10
- Steamer connection, 26
- Steel construction, 4
- Steel pipe, 21
- Steel pipe, wrought, 21
- Steel, structural, 4
- Steel vessel, 34
- Stick construction, 3
- Storage of Rubber Tires*, NFPA 231D, 2
- Storage system, high-piled, 2
- Stored Emergency Systems*, NFPA 110A, 12
- Straight-stream hose nozzle, 16
- Strainer, 30
- Stream allowance, 46
- Stream hose, 46
- Strobe light, 12
  
- Structural member, composite, 4
- Structural steel, 4
- Structures, combustible, 2
- Submersible turbine pump, 26
- Suction tank, 25
- Sump pump, 26
- Supervisory switch, 11
- Supply curve, 23
- Supply pressure, 24
- Supply pump, 26
- Suppression, explosion, 52, 53
- Switches, types of, 11
- System
  - carbon dioxide, 17
  - chemical-responsive, 53
  - circulating closed-loop, 20
  - cycle, 24
  - dust collection, 7
  - dust suppression, 7
  - explosion prevention, 50
  - flue gas desulfurization (FGD), 7
  - gridded, 20
  - halon, 16
  - hose, 15
  - hydraulic, 6
  - loop, 20
  - mechanical-responsive, 53
  - passive-mechanical isolation, 53
  - preaction dry pipe, 18
  - standpipe, 15
  - tree, 20
- System loss curve, 23
- System riser, 21
- Systems, sprinkler, types of, 17, 18, 19
  
- Tag, 22
- Tamper switch, 11
- Tank, fraction of air in, 34
- Tank, portable, 5
- Tanks, types of, 25, 34
- Tee, 36
- Teflon-coated cable, 5
- Temperature ranges, sprinkler, 29
- Temperature-rated sprinkler
  - high, 29
  - intermediate, 29
  - ordinary, 2
- Temperature ratings, sprinkler, 29
- Temperatures, ignition, 49
- Thermal properties, 3
- Timber, 2
- Tolerant, single-fault, 51
- Transformer, oil-insulated, 8
- Tree system, 20
- Tube, copper, 21
- Tubing
  - electrical metallic (EMT), 5
  - nonmetallic environmental airspace (NEAT), 5
  - water, 21
- Tubing in hydraulic systems, 6
- Turbine, gas, 8
  
- UEL, 49
- UL, 9
- Ultraviolet flame detector, 11

- Underwriters Laboratories (UL), 9
- Uniform Building Code*, 1
- Uniform Fire Code*, 1
- Upper explosive limit (UEL), 49
- Upright sprinkler, 28
- Urea-potassium bicarbonate, 15
  
- Value, heating, 3
- Valve, fast-acting gate, 53
- Valve monitor switch, 11
- Valves, types of, 22, 23, 25
- Vapor density, 49
- Velocity pressure, 37
- Vent
  - explosion, 50
  - relief, 53
  - relief, bursting-panel, 53
  - roof, 5
- Ventilation, dilution, 54
- Venting explosion, 53
- Vertical pump, 26
- Vessel, steel, 34
- Volumetric limits, 5
  
- Wallboard, gypsum, 4
- Water
  - sources of, 24
  - wet, 14
- Water-flow detector, 11
- Water hammer, 22
- Water Spray Fixed Systems*,
  - NFPA 15, 4, 19
- Water spray sprinkler system, 19
- Water-supply valve, 22
- Water tanks, types of, 25
- Water tubing, 21
- Weatherability, 13
- Wet barrel, 26
- Wet pipe sprinkler system, 17
- Wet scrubber, 7
- Wet standpipe, 15
- Wet water, 14
- Wiring, 12
- Wood frame construction, 3
- Worksheet, 42
- Wrought steel pipe, 21
  
- X-purging, 51
  
- Y-purging, 51
  
- Zoning, 12
- Z-purging, 51